

LIGHT FIXTURE SCHEDULE

FIXTURE	MANUFACTURER	CATALOG NO.	LAMPS	MOUNTING	LOCATION/REMARKS
A	LITHONIA	RC 296 120 SSB	SYLVANIA F96/T12/CW/SS	RECESSED	RECESSED STRIP LIGHT WITHOUT LENS
A1	LITHONIA	RC 248 120 SSB	SYLVANIA F40/T12/CW/SS	RECESSED	RECESSED STRIP LIGHT WITHOUT LENS
B	LITHONIA	2SPG 440 120 SSB PC2 SA	SYLVANIA F40/D41/SS	RECESSED	1/2"x1/2" SILVER PARACUBE LOUVER
C	LITHONIA	2SPG 440 120 SSB	SYLVANIA F40/D41/SS	RECESSED	
D	LITHONIA	2SPG 440 120 SSB	SYLVANIA F40/CW/SS	RECESSED	
E	LITHONIA	2SPG 340 120 SSB	SYLVANIA F40/D41/SS	RECESSED	
F	LITHONIA	SPG 240 120 SSB	SYLVANIA F40/D41/SS	RECESSED	
G	LITHONIA	ELE SB*G 120	ELECTROLUMINESCENT	WALL OR CEILING	ORDER W/O BATTERY-VERIFY NO. OF FACES
H	LITHONIA	2SPG 2U40 120 SSB	SYLVANIA FB40/D41/6	RECESSED	
J	LITHONIA	WB240 AS 120 SSB WH	SYLVANIA F40/T12/CW/SS	WALL	STAIRS
J1	LITHONIA	WB220 AS 120 SSB	SYLVANIA F20/T12/CW/SS	WALL	RESTROOMS
K	LITHONIA	AH 250M 12AR 120	SYLVANIA M250/C/U	RECESSED	
L	LITHONIA	AF 296 120 SSB CS7	SYLVANIA F96/T12/CW/SS	CEILING	
M	LITHONIA	DMW 296 HO 120 SSB	SYLVANIA F96/T12/CW/HO	CEILING	W/ 0 DEGREE BALLAST
M1	LITHONIA	DMW 296 HO 120 CW20 SSB	SYLVANIA F96/T12/CW/HO	CEILING	W/ -20 DEGREE BALLAST
N	LITHONIA	TWP 150S 208	150W H.P.S.	WALL	SIDE & BACK EXTERIOR
R	LITHONIA	KAS1 175M R4 208 WB12	175 M.H.	WALL	FRONT EXTERIOR
T	PEERLESS	QD6 102203	SYLVANIA F40/D41/SS	CABLE HUNG	8'-0" A.F.F. CORD FEED
V	LITHONIA	G2V 250M T73 208	M250/C/U	RECESSED	
VI*	LITHONIA	G2V 250M T73 QRS * 208	M250/C/U	RECESSED	
W	LITHONIA	SS2 296 120 SSB	F96/T12/CW/SS		
W1	LITHONIA	SS2 272 120 SSB	F72/T12/CW/SS		
W2	LITHONIA	SS2 248 120 SSB	F48/T12/CW/SS		
Z	LITHONIA	SEE NOTE 1 BELOW			
CC	DAYTON	2V537	150W PAR 38	WALL	DOCK LIGHT
DD**	LEVITON	9875	60W		COOLER/FREEZER
EE	(EXISTING)	-	-	CANOPY	

NOTES:

- FIXTURE "Z" SHALL CONSIST OF TWO ROWS OF FIXTURES, EACH 16' LONG. TOP ROW SHALL BE 4'-8'-4' FIXTURES. BOTTOM ROW SHALL BE 8'-8' FIXTURES. FOUR FOOT LONG FIXTURES SHALL BE TYPE "AA1" & EIGHT FOOT LONG FIXTURES SHALL BE TYPE "AA" FIXTURES WITHOUT THE HRUN1 OPTION.
- APPROVED EQUALS BY METALUX & DAYBRITE SHALL BE ACCEPTABLE.
- ALL FLUORESCENT FIXTURES ARE TO BE EQUIPPED W/ ELECTRONIC BALLAST BY MAGNETEK.

* CHECKOUT LIGHTING ON LPE CIRCUIT TO HAVE QUARTZ RESTRIKE. PROVIDE LAMP.

** FURNISHED BY REFRIGERATOR CONTRACTOR, INSTALLED BY E.C.