

GENERAL NOTES:

I. CODES AND SPECIFICATIONS

- A. GENERAL BUILDING CODE
1. International Building Code 2006
B. CONCRETE CODES
1. ACI 318, American Concrete Institute Building Code.
2. ACI 301, Specifications for Structural Concrete for Buildings.
3. CRSI - Manual of Standard Practice.
C. STRUCTURAL STEEL CODES
1. AISC - Load and Resistance Factor Design, Third Edition.
2. AISC - Steel Construction Manual, Thirteenth Edition
3. ANSII/AWS D1.1, American Welding Society - Steel.
D. MASONRY CODES
1. ACI 530 / ASCE 5
2. ACI 530.1 / ASCE 6, Specification for Masonry Structures.
E. COLD FORMED STEEL (LIGHT GAGE METAL) CODE
1. American Iron and Steel Institute (AISI) "Specification for the Design of Cold Formed Steel Structural Members", Latest Edition.
F. CONFLICTS IN STRUCTURAL REQUIREMENTS
1. Where conflict exists among the various parts of the Structural and architectural Contract Documents, (Structural Drawings, General Notes, Specifications) the strictest requirements shall govern.

All Codes and Specifications listed above shall include all amendments and addenda in force at the date of the contract documents.
II. TYPICAL DETAILS
A. Details labeled "Typical Details" on the Drawings shall apply to all situations occurring on the Project that are the same or similar to those specifically detailed. Such details shall apply whether or not they are keyed in each location. Questions regarding applicability of Typical Details shall be determined by the Engineer.
III. DESIGN CRITERIA
A. DEAD LOADS
1. Dead loads: Dead load materials assumed in the design are shown on the Architectural and Structural Drawings.
2. Partitions: An allowance of 15 psf has been made for partitions as a uniformly distributed live load, wherever partitions are used and location subject to change excluding public lobbies, corridors, restrooms, and places of public assembly.
B. LIVE LOADS
CATEGORY UNIFORM LOAD (PSF) CONCENTRATED LOAD (PSF) LOAD (#)
Roof 20 N/A
Corridors, 100 0
Exit Facilities
Guard Rails & Hand Rails 50 plf or 200 lbs, applied at top rail in any direction. Intermediate rails = 25 plf.
Stairwells, Plazas, 250 16000
Driveways subject to Traffic
Stores - Retail 75 2000
Live loads have been reduced on any member based on the Code cited in CODES AND SPECIFICATIONS, Paragraph 1. A.
C. WIND LOADS
1. Wind pressure based on the requirements of Code cited in CODES AND SPECIFICATIONS, Paragraph 1. A.
2. V = 90 mph, Exposure: B, I = 1
D. SEISMIC LOADS
1. Mapped Acceleration Parameters: Ss = 0.137, S1= 0.057.
2. Site Class = E.

IV. FOUNDATION - GENERAL
A. GEOTECHNICAL REPORT
Foundation design is based on the following geotechnical report:
Proposed Building located at Westley Street and Karl Lane in Greenville, TX.
Prepared by: Earth Engineering, Inc.
Report No. EE-016017-1
Date: February 16, 2009
All recommendations therein that relate to the work shown on these drawings shall be followed.
B. FOUNDATION APPROVAL AND INSPECTION BY AUTHORIZED INSPECTOR
1. The General Contractor shall notify the Geotechnical Engineer or other authorized inspector for review of foundation bearing surface, inspection of foundation installation, and placement of reinforcing steel. The contractor shall not place concrete without inspector's approval.
2. The Contractor shall notify the authorized inspector 24 hours in advance of any major foundation pour.
C. GRADE BEAMS
1. Grade Beam Side Forms.
a. Form exposed faces of grade beams.
2. Grade beam bottom steel shall be chaired at 5 foot maximum centers using beam bolsters providing 3 inch bottom cover to reinforcing steel. Beam bolsters used shall be intended for support on soil
3. Bottom bars of grade beam shall be spliced (where required) at the pier only. Top bars shall be spliced (where required) at the midspan of the grade beams. Lap length shall be 44 times bar diameter unless specified otherwise. Provide corner bars to match top and bottom steel.
D. SLAB-ON-GRADE CONSTRUCTION
1. Slab on grade construction shall follow the recommendations of Guide for Concrete Floor and Slab Construction ACI 302.1R.
2. Subgrade Preparation shall conform to the soils report noted above. If report does not specify the amount of select fill, provide fill as required above to reduce PVR to 1 inch.
E. VAPOR RETARDER
1. Vapor retarder shall have no more than 0.01 perms when tested in accordance with ASTM E-86; meet or exceed the requirements of ASTM E-1745, Class C, and be no less than 15mils thick in accordance with ACI 302.1R-96. Acceptable products include:
a. STEGO WRAP VAPOR BARRIER (15 mil) by Stego Industries LLC (281)367-0040
b. Grifflon T-85 by Reef Industries
c. Rulco D16WS by Raven Industries
d. Barrier-Bac VB-350 (16mil) Vapor Retarder
2. All seams shall be overlapped a minimum of 6 inches and taped with polyethylene tape. All penetrations, block-outs, and openings shall be sealed using a combination of the vapor retarder and polyethylene tape.

V. DRILLED PIER FOUNDATION
A. DESIGN SOIL PRESSURES
Allowable Pressure = 4,000 psf under sustained loads
= 6,000 psf for total (dead + live) loads
B. FIELD INSPECTION OF BEARING STRATUM
1. The bearing stratum of each drilled pier shall be inspected and approved by the Geotechnical Engineer or other authorized inspector prior to pouring of concrete.
2. The bottom elevation of pier is as shown on the Drawings for pier proposals. The actual required bearing elevation may vary as required to provide proper capacity as determined by the geotechnical engineer. Footings shall be poured immediately after excavation.
3. Provide and install 1/8 inch steel templates to accurately set vertical pier reinforcing steel, and anchor bolts for steel columns.

VI. CONCRETE
A. CLASSES OF CONCRETE
1. All concrete shall conform to the requirements as specified in the table below unless noted otherwise on the Drawings:
USAGE 28 DAY COMP. CONC. TYPE MAX. SIZE AGGREGATE STRENGTH (PSI)
Footings, Grade Beams, Piers 3000 NW 1 1/2"
Slab-on-Grade 3000 NW 1 1/2"
Drilled Piers (under reamed) 3000 NW 1 1/2"
Note: NW = Normal weight concrete
2. There shall be no horizontal cold joint in any concrete pour.
3. Admixtures used shall be compatible with floor treatments.
4. Concrete for slab-on-grade shall have a maximum water-cement ratio of 0.50.
5. Concrete shall comply with the requirements of ACI 301 and ACI 318.
6. Fly ash conforming to ASTM C618, Type F, may be used unless noted otherwise. The maximum amount of fly ash shall be 25% of the total cementitious material by weight.
7. Concrete shall comply with the requirements of ACI 301 and ACI 318.

VII. REINFORCING STEEL
A. SPECIFICATION
1. ASTM A 615 Grade 60 unless noted otherwise on the drawings.
B. REINFORCING STEEL COVERAGE
Cover in structural members not specified below shall conform to the requirements of ACI 318 Section 7.7 unless specified otherwise on the drawings.
1. Foundation Members
a. Grade Beams 1 1/2" top, 3" bottom, 3" sides
b. Foundation Retaining Walls 2" both faces
c. Sump Walls, Pit Walls 2" both faces
d. Drilled Piers 3" sides
e. Interior Slab-on-Grade see details
f. Exterior Slab-on-Grade 2" top cover for one layer of steel, 2" top cover, 3" bottom cover for two layers of steel.

VIII. STRUCTURAL STEEL
A. MATERIAL
1. All hot rolled steel plates, shapes and bars shall be new steel conforming to ASTM Specification A6-84.
2. All wide flanged beams shall conform to ASTM A992, Grade 50.
3. All wide flanged columns shall conform to ASTM A992, Grade 50.
4. All tubes shall conform to ASTM A500 Grade B.
5. All pipe columns shall conform to ASTM A53, Grade B or ASTM A515.
6. All connection material shall conform to ASTM A36 unless stronger required.
B. CONNECTIONS
1. Typical connection details are indicated on the Drawings.
2. The design of all steel connections shall be performed under the direct supervision of a registered professional engineer in the state where the project is located, employed by the fabricator. Calculations sealed by the fabricator's professional engineer must be submitted if requested.
3. It is the intention of the plans and specifications that shop connections be welded or bolted and that field connections be bolted, unless detailed otherwise on the Drawings.
4. All typical beam simple connections shall be standard double angle or single angle framed beam connections. Shear tab connections may be used at locations where double angle connections are not possible. Seated beam connections shall not be used unless indicated on the Drawings. Provide full depth shear tab if beam frames on only one side of a girder.
5. Beam Reactions
a. Non-Composite beams: Design connections to support a reaction R (unless specified otherwise) equal to one half the total uniform load capacity from the table of Uniform Load Constants in the AISC Manual.
6. Bracing connections shall develop full tensile forces at each end of the bracing member unless bracing forces are specified on the Drawings.
7. MC = Moment Connections
8. Welds:
a. All welds shall conform to the American Welding Society (AWS) standards.
b. All welding shall be performed by a welder certified in accordance to the AWS standards.
9. Bolts:
a. All bolts shall conform to ASTM A325 Type 1, High Strength Bolts. All bolts shall be designed as bearing bolts with threads included in the shear plane. Minimum bolt diameter shall be 3/4 inch. All bolts shall be tightened to a snug tight position, unless noted below.
b. All bolts at bracing and moment connections shall be tightened using load indicating washers or tension bolts.
c. All bolts shall be new and shall not be re-used.

C. GALVANIZING
1. All steel exposed to weather or outside the building's waterproofing, such as brick shall angles, shall be hot-dipped galvanized after fabrication.
2. All steel surfaces to be hot dip galvanized shall be prepared as specified by the Steel Structures Painting Council (SSPC).
The coating for steel shapes and plates shall average not less than 2.3 oz. with no individual thickness less than 2.0 oz.
4. Galvanize all nuts, bolts, and washers used in the connection of galvanized steel.
5. Protect all field welded connections with "Z.R.C. Cold Galvanizing Compound" as manufactured by Z.R.C. Product Company.
D. MISCELLANEOUS - STAIRS AND HANDRAILS
1. Handrails and guardrails (including attachment to structure) shall be designed by the fabricator for the loads indicated in the referenced Building Code. Shop drawings shall be sealed by a Professional Engineer in the state of Texas, representing the fabricator.
2. Stairs shall be designed by the fabricator for code required loads. Shop drawings shall be sealed by a Professional Engineer in the state of Texas, representing the fabricator.

IX. NON-SHRINK GROUT FOR BASE PLATES AND BEARING PLATES
A. SPECIFICATIONS
1. Grout for base plates and bearing plates shall be a non-metallic, shrinkage resistant, prepacked, non-corrosive, non-staining product containing Portland cement, silica sands, shrinkage compensating agents, and fluidity improving compounds.
2. Grout shall conform to Corps of Engineers Specification for Non-Shrink Grout, CE-CRD-C621. Twenty-eight day compressive strength as determined by grout cube tests, shall be 5,000 PSI. Minimum thickness of grout under all base plates and bearing plates shall be 1 inch, unless specified otherwise on the drawings.
3. Grout shall be placed in a fluid flowable state under base plates that have a form built around them for grout confinement. Grout should be cured according to manufacturer's recommendations.

X. STEEL ROOF DECK (WITH RIGID INSULATION BOARD)
A. SCHEDULE
1. Roof deck shall be 1.5B(22 gauge) as manufactured by Vulcraft, or equivalent.
B. SPECIFICATION
1. The design, fabrication, and erection of all roof deck shall conform to the Steel Deck Institute Design Manual for Composite Decks, Form Decks, and Roof Decks as published by the Steel Deck Institute (SDI).
2. Steel deck shall be manufactured from steel conforming to ASTM A 653-94 structural quality grade 33 or higher.
3. Steel deck shall be galvanized with a protective zinc coating conforming to ASTM A 653-94 G90 class.
C. ATTACHMENT
1. Roof deck units shall be welded to each structural support member using 5/8 inch diameter puddle welds at all fits where sides lap and each fit in between (3/67 pattern). Weld metal shall penetrate all layers of deck material at end laps and side joints and shall have good fusion to the supporting members. At perimeter, deck shall be welded at 6" o.c.
2. Side laps of adjacent units shall be fastened by sheet metal screws so that spacing between supports and fasteners does not exceed 12 inches.
3. Provide a minimum end bearing of 2 inches over supports.
4. End laps of sheets shall be a minimum of two inches and shall occur over supports.
5. Provide roof deck construction which is listed and conforms to the UL Fire Resistance Directory and Building Materials Directory. Deck attachment shall be increased above the minimum specified herein as required to achieve a Class 90 uplift rating.
D. DECK SPANS
1. Metal deck spans shall not exceed the maximum center to center spans as required by SDI criteria. Where possible, all metal deck shall extend over three or more supports. Two span deck shall be used only where deck layout does not permit the use of three spans. Single span deck is not permitted.
E. ACCESSORIES
1. Provide minimum 20 gauge ridge and valley plates, minimum 20 gauge cant strips, minimum 14 gauge sump pans, minimum 20 gauge inside or outside closure channels, minimum 20 gauge butt strips at change of deck directions, minimum 20 gauge filler sheets, and rubber closures as required to provide a finished surface for the application of insulation and roofing.
F. ROOF OPENINGS
1. Roof openings less than 6 inch square or diameter require no reinforcement. Openings 6 inch to 10 inch inclusive shall be reinforced with a 20 gauge galvanized plate welded to the deck at each corner and 8 inch maximum centers with a 5/8 inch diameter puddle weld or sheet metal screws. Unless indicated otherwise on the drawings, openings over 10 inch wide or diameter shall be reinforced with an angle 2 1/2 x 2 1/2 x 1/4 framing each side of the opening and spanning between supports for spans 4 feet or less and L 3 x 3 x 1/4 for spans greater than 4 feet but less than 6 feet unless specified otherwise on drawings. Larger openings shall be referred to the Engineer for framing.

XI. SUBMITTALS
A. SHOP DRAWINGS
1. The General Contractor shall submit for Engineer review shop drawings for the following items:
a. Structural Steel (*)
b. Reinforcing Steel
c. Metal Deck
d. Concrete Mix Designs
e. Miscellaneous Steel
Items marked (*) shall have shop drawings sealed by a registered engineer in the state where the project is located. Items marked (R) shall be submitted to Engineer for Owner's record only and will not have Engineer's shop drawing stamp.
2. All shop drawings must be reviewed and sealed by the General Contractor prior to submittal.
3. Contractor shall submit one set of sepias and two sets of blue-line prints for all shop drawings specified to be returned by the Engineer.
4. The omission from the shop drawings of any material required by the Contract Documents to be furnished shall not relieve the contractor of the responsibility of furnishing and installing such materials, regardless of whether the shop drawings have been reviewed and approved.
B. MANUFACTURER'S LITERATURE
1. Submit two copies of manufacturer's literature for all materials and products used in construction on the project.
C. REPRODUCTION
1. The use of reproductions of these Contract Documents by any contractor, subcontractor, erector, fabricator, or material supplier in lieu of preparation of shop drawings signifies his acceptance of all information shown herein as correct, and obligates himself to any job expense, real or implied, arising due to any errors that may occur hereon.

XII. MISCELLANEOUS
A. CONTRACT DOCUMENTS
1. It is the responsibility of the General Contractor to obtain all Contract Documents and latest addenda and to submit such documents to all subcontractors and material suppliers prior to the submittal of shop drawings, fabrication of any structural members, and erection in the field.
B. DRAWING CONFLICTS
1. The General Contractor shall compare the Architectural and Structural drawings to the drawings. All discrepancies between each set of drawings and within each set of drawings to the Architect and Engineer prior to the fabrication and installation of any structural members.
C. EXISTING CONDITIONS
1. The General Contractor shall verify all dimensions and existing conditions at the job site and report any discrepancies from assumed conditions shown on the drawings to the Architect and Engineer prior to the fabrication and erection of any members.
D. RESPONSIBILITY OF THE CONTRACTOR FOR STABILITY OF THE STRUCTURE DURING CONSTRUCTION
1. All structural elements of the project have been designed by the Structural Engineer to resist the required code vertical and lateral loads that could occur in the final completed structure only. It is the responsibility of the Contractor to provide all required bracing during construction to maintain the stability and safety of all structural elements during the construction process until the structure is tied together and completed.
E. HORIZONTAL CONSTRUCTION JOINTS IN CONCRETE POURS
1. There shall be no horizontal construction joints in any concrete pours unless shown on the drawings. All deviations or additional joints shall be approved in writing by the Architect/Engineer.

XIII. SITE OBSERVATION BY THE STRUCTURAL ENGINEER
A. GENERAL
1. The contract structural drawings and specifications represent the finished structure, and except where specifically shown, do not indicate the method or means of construction. The Contractor shall supervise and direct the work and shall be solely responsible for all construction means, methods, and procedures, techniques, and sequences.
2. The Engineer shall not have control or charge of, and shall not be responsible for, construction means, methods, techniques, sequences, or procedures, for safety precautions and programs in connection with the work, for the acts or omission of the Contractor, Subcontractor, or any other persons performing any of the work, or for the failure of any of them to carry out the work in accordance with the contract documents.
3. Periodic site observation by field representatives are solely for the purpose of determining if the work of the Contractor is proceeding in accordance with the structural contract documents. This limited site observation should not be construed as exhaustive or continuous to check the quality or quantity of the work, but rather periodic in an effort to guard the Owner against defects or deficiencies in the work of the Contractor.

XIV. LIGHT GAGE METAL
A. SPECIFICATIONS
1. All structural members and connections shall be designed and erected per the American Iron and Steel Institute (AISI) Specifications noted above.
2. All studs and/or joists and accessories shall be of the type, size, gauge and spacing shown on the Drawings. All joists and studs shall have 1 5/8" flange with 1/2" return unless specified otherwise.
3. All framing members shall be manufactured from corrosion resistant steel conforming to ASTM A 653 (G90) with a minimum yield strength of 50 ksi for studs and joist members and 33 ksi for runner and track members and flat strap bracing.
4. Prior to fabrication, the contractor shall submit erection drawings to structural engineer for review and approval.
5. All framing components shall be cut squarely for attachment to perpendicular members, or as required for an angular fit against abutting members.
B. DESIGN
1. Fastening of components shall be with self-drilling screws or welding of sufficient size to ensure the strength of the connection.
2. Studs shall have full bearing against inside track web, prior to stud and track attachment.
3. Sockets in framing components except runners track shall not be permitted.
4. For non-load bearing studs, connections shall consider the deflection (1/2") of structural members to which the studs are attached. Provide slide clips and/or deflection slip tracks.
5. The design of all light gage metal shall be performed by the light gage metal contractor. The design shall include member sizes and connections. The design shall consider member dimensions noted in the drawings. The light gage contractor shall supply drawings sealed by an engineer registered in the State where the project is located showing light gage framing members and connection. The out plane deflection of studs shall be limited to H/60 (H = unspaced height of studs) if used for masonry or stone backup. For other conditions deflection shall be limited to H/360.
C. ERECTION
1. Erect framing and panels plumb, level and square in strict accordance to approved shop drawings.
2. Track shall be securely anchored to the supporting structure. Proposed connection to be submitted for approval unless specified otherwise on drawings. Abutting pieces of track shall be securely spliced together.
3. Jack studs or cripples shall be installed below window sills, above window and door heads, and elsewhere to furnish support, and shall be securely attached to connecting members.
4. Provide horizontal bridging in all stud systems at four feet on centers vertically for axially loaded studs, and at six feet on centers vertically for non-load bearing studs. Weld at each stud intersection.
5. Provide diagonal steel straps of size and location shown on the drawings. Extend straps from the bottom track to the top track inclined 45 degrees unless shown otherwise and connected to each stud.
6. Provide stud bracing during construction as required for studs to carry construction loads.
7. At the load bearing walls supporting floor or roof joists, locate studs directly under the joists or provide load distributing member between studs to support joists.

XVIII. CONCRETE MASONRY
A. SPECIFICATION
1. All masonry materials and construction shall conform to the recommendations of the Brick Institute of America (BIA) and National Concrete Masonry Association (NCMA) and masonry codes noted in these general notes.
2. All concrete masonry units (CMU) shall conform to ASTM C90, Type 1, Grade N. Unless specified otherwise, CMU shall be lightweight (less than 105 PCF, oven dry unit weight).
3. Mortar:
a. Unless specified otherwise, all mortars and the materials therein shall conform to the standard specifications of Masonry Units, ASTM C270, Type S except for masonry in contact with the earth shall be Type M.
b. Mortar shall have minimum average strength of 2500 psi for Type M, and 1800 psi for Type S.
4. Grout.
a. All Grout shall be fine grout containing sand, Portland cement, and lime (optional) for grout spaces less than 2 inches in any horizontal direction, unless specified otherwise.
b. Grout shall attain a minimum 28 days compressive strength of 2500 psi tested according to ASTM C39.
5. Control Joints shall be located per Architectural drawings and specifications or at a maximum spacing of 40 feet on centers.
B. REINFORCEMENT
1. Provide horizontal reinforcing (truss or ladder type) at 16 inches on center for all CMU walls. Reinforcement shall conform to ASTM A62 and shall be hot dip galvanized.
2. All horizontal reinforcing steel in bond beams and lintel block units shall be continuous. Units shall be solidly grouted. Provide 48 times bar diameter lap for horizontal reinforcing in bond beams. No splices shall be provided for horizontal reinforcing in block lintels.
3. Grout cells solid where vertical bars are shown on the drawings. Vertical bars shall extend from bottom to the top of the wall. Provide 48 times bar diameter splice for vertical bars where required and/or shown on the Drawings.
4. All reinforced masonry walls with openings up to four (4) feet wide, shall have one vertical bar minimum at each side of openings. For openings larger than 4 feet wide, provide two (2) vertical bars at each side of openings. Reinforcing at edges of opening shall match typical vertical wall reinforcing (unless noted otherwise) and shall extend to the top of wall.
5. All reinforced masonry wall corners and intersections shall have one vertical bar (minimum) in grouted cell. Reinforcing shall match typical wall vertical reinforcing.
6. Provide one vertical bar (minimum) in the first cell each side of control joints. Reinforcing shall match typical vertical wall reinforcing (unless noted otherwise) and shall extend to the top of wall.
C. SPECIAL INSPECTION
1. Special inspection, in accordance with the building code referenced above.

ISSUED FOR CONSTRUCTION OCTOBER 8, 2014

WINDLE + VOLPPE ARCHITECTS

NO. 00101, TEAM 77063 PH 713-925-1990 7600 GRIFFITH

MATRIX STRUCTURAL ENGINEERS 24 GREENWAY PLAZA SUITE 1500 HOUSTON, TEXAS 77046-2401 PHONE: (713) 664-0130 FAX: (713) 664-1370

MATRIX Structural Engineers Inc. License No. FE-2640 DRAWINGS INCOMPLETE THIS DOCUMENT FOR REVIEW ONLY. NOT INTENDED FOR PERMITTING, BIDDING, OR CONSTRUCTION PURPOSES. MOYEENUL HAQUE 72876 DATE: 05-30-13

ROSS SHELL CROSSROADS MALL GREENVILLE, TEXAS GREENVILLE PROPERTIES LTD. GREENVILLE, TEXAS

DATE 5/20/2013 PROJECT NO. 08-12-02 DRAWN BY

GENERAL NOTES S1.0