



GAS DEMAND SCHEDULE	
RTU-1	240 CFH
RTU-2	240 CFH
RTU-3	180 CFH
RTU-4	180 CFH
RTU-5	125 CFH
TOTAL DEMAND	965 CFH = 965,000 BTUH

NOTE:  
 COORDINATE GAS DEMAND REQUIREMENTS WITH  
 SITE-SPECIFIC RTU DESIGN.

PIPE SIZE BASED ON 400' OF PIPE AND 7" W.C.