

# WINDLE + VOLPE ARCHITECTS

June 28, 2013

Michael Johndrow  
The TJX Companies, Inc.  
Architecture & Engineering Department  
770 Cochituate Road  
500 OCPD1  
Framingham, MA 01701

Reference: Marshalls  
Crossroads Mall  
Greenville, Texas

Dear Mr. Johndrow;

We have complied with the following Plan Review Comments for the Marshalls at Crossroads Mall in Greenville, Texas.

## **SHEET A2-1**

1. Existing doors are not to be welded shut. Remove doors and infill with CMU to match existing exterior.
2. Not the compactor to be concrete slab to be 10' wide by 40' in length.
3. Change door number 31 to 30.

## **SHEET A6-1**

1. Interior elevation I-East has been revised.
2. Finish call outs to be revised per drawing mark-up.

## **SHEET M1.0**

1. Duct sox no longer used . Use spiral duct work in processing room.
2. Change RTU-6 and 9 to three ton .
3. Provide 50 CFM s/a to cash hallway.
4. Condition cash and LP office from RTU-1.
5. Omit EF-7.
6. Sales floor RTU's to have power exhaust.

## **SHEET M2.1**

1. Flex duct not to exceed 4'-0" in length.
2. All roof curbs to have burglar bars.

**SHEET E1.2**

1. Show POS and systems rack on DP circuits.
2. Omit GRI receptacles in toilet rooms.

**SHEET E1.4**

1. Omit EF-7 and EUH-2.
2. RTU 6 and 9 to be three ton units.

**SHEET E1.6**

1. Main distribution panel to be 600 AMP service.
2. Revise DP panel and electrical riser per POS and UPS insets placed on drawing.
3. Incorporate sheet C-7 from TJX criteria set to be part of electrical drawings.

**SHEET E1.7**

1. Revise panel circuiting and voltage/ phase per mark-up.

**SHEET P1.1**

1. Show Guardian eye wash on plumbing schedule.
2. Toilet flush valves to be Sloan G2-8111.
3. Urinal flush valves to be Sloan G2-8186.
4. Lavatory faucets to be Sloan EBF-650.

**SHEET P1.2**

1. Show all gas piping.

**SHEET P1.3**

1. Show water to eye wash (hot and cold).
2. Show water to ice maker in lounge.

Please feel free to contact us if you have any additional questions.

Thank you,

Amy Pelton, LEED AP BD&C, CDT  
WINDLE + VOLPE Architects  
7600 San Felipe  
Houston, Texas 77063  
Phone: 713-255-1390

**WINDLE + VOLPE**  
ARCHITECTS