

WINDLE + VOLPE
ARCHITECTS

Addendum

02

Date: November 13, 2014

Reference: Marshalls Interior Build-out Package
Crossroads Mall
6834 Wesley Street, Suite E
Greenville, Texas 75402

Owner: Greenville Properties
10850 Wilshire Blvd., Suite 1050
Los Angeles, California, 90024

Architects Project No. 08-12-01m

Notice to Bidders:

1. This Addendum shall be considered part of the Bidding Documents for the above mentioned project. Where these revisions differ from the original Bidding Documents, this Addendum shall govern and take precedence.
2. Bidders shall make all necessary adjustments in their estimates in accordance with this Addendum
3. Bidders shall acknowledge receipt of this Addendum on the Bid Form, and it is presumed that each Bid submitted includes all supplementary information, revisions, and alterations provided in this addendum.

The following is a description of the changes provided in this Addendum:

ALL DRAWINGS

1. All drawings have been stamped "Issued for Construction".

ARCHITECTURAL:

SHEET 0-1 COVER SHEET

2. Revised the index of drawings.
(See attached 30"x42" sheet A0-1)

SHEET A2-1 FLOOR PLAN

1. Added missing arrow to note on the Floor Plan.
2. Added dimension to Manager's Hall to clarify TAS requirements.
3. Added reference to enlarged fitting room plans on sheet A10-1.
4. Revised clear dimension required at Kitchen Elevation (detail #2) to comply with Texas Accessibility Standards.

(See attached 30"x42" sheet A2-1)

SHEET A10-1 FIXTURE FLOOR PLAN

1. Corrected the North arrow on detail #1.
2. Added three dimensions at the Kitchen area (detail #1) to clarify clearances required to comply with Texas Accessibility Standards.
3. Added detail #2 to clarify accessibility requirements for the fitting rooms.

(See attached 30"x42" sheet A10-1)

ELECTRICAL:

SHEET E1.1 LIGHTING FLOOR PLAN, LIGHT FIXTURE SCHEDULES & DETAILS.

1. Coordinate final signage j-box locations with Marshall's sign vendor.
(Sheet not revised)

PLUMBING:

SHEET P1.1 PLUMBING FLOOR PLAN

1. Note: Match sump pump specifications as provided in the Crossroads Mall Back of House Package and coordinate with Marshalls Shell Package.
(Sheet not revised)

SHEET P1.3 DETAILS

1. Per Tenant Comments:
Ice Maker has been deleted, therefore delete 1/2" CWS to Ice Maker (Keyed note #4).
(Sheet not revised)

End of document