



FIRE / SECURITY PLAN
SCALE: 1/8"=1'-0"

ROOM NUMBER	ROOM NAME	CEILING HEIGHT
100	GENERAL SALES	11'-2"
101	ENT. VESTIBULE	12'-0"
102	FITTING ROOM	11'-2"
103	STOCK ROOM	11'-2"
104	CORRIDOR	9'-0"
105	MALE RESTROOM	9'-0"
106	FEMALE RESTROOM	9'-0"
107	JANITOR	9'-0"
107A	OFFICE SUPPLIES	9'-0"
108	CASH/AUDIT	9'-0"
109	MARKING/RECEIVING	
110	ASSOC. ENTRANCE	9'-0"
111	CONFER. ROOM	9'-0"
112	ASSOC. LOUNGE	9'-0"
113	ASM UTILITY	9'-0"
114	CORRIDOR	9'-0"
115	MANAGER OFFICE	9'-0"
116	COPIER/MAIL	9'-0"
117	TELE-COMMUN.	9'-0"
118	ELEC. SWITCHGEAR	9'-0"
119	FITTING ROOM	11'-2"
120	STOCK	11'-2"
121	SPRINKLER ROOM	11'-2"
122	FITTING ROOMS	11'-2"
123	CORRIDOR	11'-2"
124	STOCK	11'-2"
125	CORRIDOR	11'-2"
126	STOCK	11'-2"
127	ELECTRICAL ROOM	11'-2"
128	STOCK	11'-2"
129	STOCK	11'-2"
130	CORRIDOR	11'-2"
131	FITTING ROOMS	11'-2"
132	FITTING ROOMS	11'-2"
133	STOCK	11'-2"
134	STOCK	11'-2"
135	STOCK	11'-2"
136	FITTING ROOMS	11'-2"

- FIRE ALARM/SECURITY SYSTEM SYMBOLS
- Ⓜ CEILING MOUNTED MOTION DETECTOR
 - Ⓜ-L CEILING MOUNTED MOTION DETECTOR (LONG RANGE MOTION BEAM)
 - Ⓜ_W WALL MOUNTED MOTION DETECTOR
 - Ⓜ_D DOOR ALARM CONTACT
 - Ⓜ_{GB} GLASS-BREAK DETECTOR
 - Ⓜ_{HB} HOLD-UP BUTTON (UNDER COUNTER)
 - Ⓜ_{BFC} BURGLAR/FIRE ALARM CONTROL PANEL
 - Ⓜ_{AKP} ALARM SYSTEM ON/OFF KEY PAD
 - Ⓜ_{EK} EMPLOYEE ENTRANCE KEY-PAD
 - Ⓜ_{BAP} BURGLAR ALARM ANNUNCIATOR PANEL (PBX DESG)
 - Ⓜ_{ESD} EXIT SECURITY DEVICE
 - Ⓜ_{FSTS} FLOW SWITCHES AND TAMPER SWITCHES
 - Ⓜ_{PS} PULL STATION NUMBER INDICATES ZONE
 - Ⓜ_{ADA-HS} ADA HORNSTROBE - CEILING MTD.
 - Ⓜ_{ADA-W} ADA HORNSTROBE - WALL MTD.
 - Ⓜ_{ADA-ST} ADA STROBE-WALL MOUNTED 80' APF
 - Ⓜ_{SD} SMOKE DETECTOR
 - Ⓜ_{DMSD} DUCT MOUNTED SMOKE DETECTOR
 - Ⓜ_{OCS} OVER-HEAD COILING SECURITY DOOR

