

TYPE	QUANT. OF FIXTURES SEE NOTE 14	MANUFACTURER & CATALOG NO.	SYLVANIA LAMPS (SEE SPECIAL NOTE)	MOUNTING	SHIELDING	TYPE	REMARKS	TYPE	QUANT. OF FIXTURES SEE NOTE 14	MANUFACTURER & CATALOG NO.	SYLVANIA LAMPS (SEE SPECIAL NOTE)	MOUNTING	SHIELDING	TYPE	REMARKS
'DDA'		LITHONIA WW-62-217-RDL-OSIS-DGA12 OR EQUAL	TWO F032/730K T8 OCTRON	RECESSED	10 CELL PARABOLIC LOUVER	FLUORESCENT	9' X 4' ASYMMETRIC DISTRIBUTION FLANGED TYPE FIXTURE WITH ONE TRIAD ELECTRONIC BALLAST.								
'DDA3'		SAME AS 'DDA' EXCEPT 3 FT. UNIT	TWO F025/730K T8 OCTRON	RECESSED	PARABOLIC LOUVER	FLUORESCENT	9' X 3' ASYMMETRIC DISTRIBUTION FLANGED TYPE FIXTURE WITH ONE TRIAD ELECTRONIC BALLAST.								
'DDSI'		LITHONIA 99MO-F-B-232-HOLD-SYM-277 OR EQUAL	TWO F032/730K T8 OCTRON	RECESSED	10 CELL PARABOLIC LOUVER	FLUORESCENT	9' X 4' SYMMETRIC DISTRIBUTION FLANGED TYPE FIXTURE WITH ONE TRIAD ELECTRONIC BALLAST.								
'W3'		INDY 316-W (WHITE)	50PAR20/CAP/NSP-130V	TRACK	NONE	INCANDESCENT	WHITE TRACK AND TRACK HEADS. LENGTH OF TRACK AND NUMBER OF HEADS AS INDICATED ON PLANS. MT. HEADS 4" - 0" ON CENTER STARTING 12" FROM END.								

**GENERAL LIGHTING FIXTURE NOTES:**


- ALL ELECTRONIC BALLASTS FOR T-8 SYSTEMS SHALL BE MANUFACTURED BY OSRAM/SYLVANIA (EXCEPTIONS MUST BE APPROVED IN WRITING.)
- CONTRACTOR SHALL DETERMINE FOR WHICH FLUORESCENT STRIP LIGHT FIXTURE SHALL HOUSE THE "MASTER" ELECTRONIC BALLAST & USE MAXIMUM NUMBER OF SLAVE UNITS POSSIBLE FOR TANDEM WIRING.
- EMT, JUNCTION BOXES, OR FLEXIBLE CONDUIT SHALL NOT BE SUPPORTED FROM THE CEILING GRID.
- ALL LIGHTING FIXTURES SHALL BE FURNISHED COMPLETE WITH ALL MOUNTING ACCESSORIES, PROVIDE HOLD DOWN CLIPS ON ALL RECESSED LAY-IN TYPE FLUORESCENT FIXTURES.
- ALL FLUORESCENT LAMPS SHALL BE SYLVANIA OCTRON T8 3000K, NO EXCEPTIONS.
- MANUFACTURERS INDICATED IN PARENTHESES, INDICATE EQUIVALENT MANUFACTURERS ACCEPTABLE TO BELK / LEGGETT.
- SEE ARCHITECT FOR EQUIVALENT FIXTURES WHERE NOT SHOWN ON LIGHTING FIXTURES SCHEDULE, PRIOR TO BID, SEE NO. 11.
- ALL LIGHTING FIXTURES SHOWN ABOVE SHALL BE PROVIDED BY ELECTRICAL SUBCONTRACTOR, UNLESS OTHERWISE INDICATED.
- ELECTRICAL SUBCONTRACTOR SHALL PROVIDE PROPER LENGTH OF VALANCE LIGHTING TO OBTAIN MAXIMUM FILL IN VALANCE SPACE.
- LENS THICKNESS FOR ALL FLUORESCENT LIGHTING FIXTURES SHALL BE - .156", MINIMUM.
- BEFORE ANY SUBSTITUTIONS WILL BE CONSIDERED A SUBSTITUTION LIST SHALL BE PRESENTED TO THE ARCHITECT A MINIMUM OF 10 (TEN) DAYS BEFORE BID DUE DATE. MANUFACTURERS SUBMITTED AFTER BID DATE WILL NOT BE ACCEPTED.
- ALL INCANDESCENT LIGHTING FIXTURES SHALL HAVE THERMAL PROTECTION WHERE REQUIRED BY NEC.
- ALL 2 FT X 4 FT AND 2 FT X 2 FT LAY-IN FIXTURES SHALL HAVE ONE TIE WIRE TIED TO FIXTURE AT ONE END AND TO STRUCTURE ABOVE.
- ELECTRICAL SUBCONTRACTOR SHALL PROVIDE ANGLE IRON SUPPORT ABOVE CEILING FOR TRACK LTG. CHANNEL. THIS SUPPORT SHALL BE SECURED TO ROOF STRUCTURAL STEEL, INDEPENDENT OF O.L.G. GRID SYSTEM.
- QUANTITIES OF FIXTURE TYPES ARE BASED ON PLANS ISSUED AT ORIGINAL ARCHITECTURAL DATE. ELECTRICAL SUBCONTRACTOR SHALL VERIFY QUANTITIES BY TYPE PRIOR TO PURCHASE AND PROVIDE LIST OF EACH TYPE FOR BELK/LEGGETT PURCHASE AND QUANTITIES OF LAMPS.
- FOR ELECTRONIC BALLASTS, THE MAXIMUM LEAD LENGTH SHALL BE IF, EXTENSIONS TO LEAD WIRE MUST BE #18 AWG OR LARGER DIAMETER COPPER WIRE WITH AN INSULATION RATING OF 600V AT 105°C.
- SPECIALTY UNIT & LAMP - VERIFY WITH INTERIOR PLANNING - LAMP PRIOR TO ORDER.

**NOTE FOR ALL "K4" LIGHT FIXTURES (TYPES "H2", "H3", "H4", "H8", "K2", "K3" SIMILAR)**

1. EVERY OTHER 4 FT. 2-LAMP FIXTURE HAS ONE 4-LAMP ELECTRONIC BALLAST. CONTRACTOR SHALL DETERMINE WHICH FIXTURE SHALL HOUSE THE "MASTER" ELECTRONIC BALLAST.

**\*\* SPECIAL NOTE \*\***

ALL LAMPS SHALL BE PURCHASED BY BELK STORES SERVICES AND TURNED OVER TO THE ELECTRICAL SUBCONTRACTOR FOR INSTALLATION. ELECTRICAL SUBCONTRACTOR ASSUMES RESPONSIBILITY OF LAMPS UPON RECEIPT OF SAME FROM GENERAL CONTRACTOR. ELECTRICAL SUBCONTRACTOR IS RESPONSIBLE FOR BREAKAGE AND HANDLING UPON RECEIPT FROM GENERAL CONTRACTOR.



Expiration: 7/31/99  
Affixed: 2/17/99

**RPDC**  
 RETAIL PLANNING DESIGN GROUP  
 2010 W. UNIVERSITY BLVD., SUITE 100, GREENVILLE, SC 29615  
 TEL: 803.235.1100 FAX: 803.235.1101

**WAS & KENNEDY ENGINEERS, P.A.**  
 ELECTRICAL ENGINEERS  
 1000 W. 10TH ST., SUITE 200, GREENVILLE, SC 29615  
 TEL: 803.235.1100 FAX: 803.235.1101

CONSULTANTS  
 PROJECT: BELK STORES MALL GREENVILLE, SC  
 SHEET TITLE: FIXTURE SCHEDULE (CONTINUED)  
 SHEET NO.: 1 OF 4

PROJECT: BELK STORES MALL GREENVILLE, SC  
 SHEET TITLE: FIXTURE SCHEDULE (CONTINUED)  
 SHEET NO.: 1 OF 4

SHEET TITLE: FIXTURE SCHEDULE (CONTINUED)  
 SHEET NO.: 1 OF 4

REVISION	DATE	BY	DESCRIPTION
1			
2			
4			

INTERIOR PLANNING SHEET NUMBER  
 OF SHEETS  
 ARCHITECTURAL SHEET NUMBER  
**E-1A**  
 OF 4 SHEETS